



BSRIA Inc.
225 West Washington Street, Office 2218, Chicago, Illinois, 60606, USA
T: +1 312-753-6800
E: sales@bsria.com | W: www.bsria.com

Mr Mark Hendrix
Skidmore
1875 Dewey Avenue
Benton Harbor, Michigan 49022

Our Ref: 58992/1

21st February 2017

Dear Mr Hendrix

Skidmore X-POT

Further to our discussion and examination of the information you supplied in relation to the design and operation of the X-POT series of products (X-POT Compact, X-POT6 and X-POT XP) I can confirm that these combination products meet the intent of BSRIA guides BG 29 *Pre-commission cleaning of pipework systems* and BG 50 *Water treatment for closed heating and cooling systems* for products providing side stream filtration and chemical dosing capabilities as referenced in the following sections of those guides when installed in accordance with your instructions:

Side stream filtration	BG 29 section 2.3.5 & BG 50 section 2.4.2
Chemical dosing	BG 29 section 2.3.5 & BG 50 section 2.4.3

The additional features of the products are consistent with the descriptions in BG 50 including:

Magnetic filtration	BG 50 section 5.1.3
Disposable media filters	BG 50 section 5.1.5
Passive deaeration	BG 50 section 5.2.1

Yours sincerely

Tom Garrigan
Manager Test House